

FIRE SAFETY CERTIFICATE

No. FSR/FS/N 24 PGS DIVN/125/16

Dated: 20/05/2024

Certified that Agarpara Swami Vivekananda Academy at 3, B. T. Road, Agarpara, Kolkata 700058 comprised of Two Numbers of adjoining Block of G+II storied as Block A and G+IV Storied as Block B owned/ occupied by Agarpara Swami Vivekananda Academy under Ramakrishna Vivekananda Mission have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 18/04/2024 in the presence of Kousik Chattaraj, Principal of Agarpara Swami Vivekananda Academy and that the building/ premises is fit for occupancy upto classes X With effect from 20/05/2024 for a period of 03 (Three) years in accordance with rule and subject to compliance of specific conditions as appended:-

- 1.
- 2.
- 3.
- 4.

Issued on 03/06/2024 at the Office of the Municipal Councillors of Panihati by CHAIRMAN, Panihati Municipality

Signature with Seal:

Name : MALAY ROY

Designation : CHAIRMAN

Name & Address of Department/ Office: PANIHATI MUNICIPALITY

Panihati, 24 Parganas (N), Pin - 700114

Malay Roy
Chairman
Panihati Municipality

Chairman
Panihati Municipality

To

The Principal

Agarpara Swami Vivekananda Academy

A Unit of Ramakrishna Vivekananda Mission

3, B.T. Road, Agarpara, North 24 Parganas, Kolkata - 700058



Chattaraj

(Kousik Chattaraj)

Principal

Agarpara Swami Vivekananda Academy
Kolkata-700058

Swami Nityarupananda
(Swami Nityarupananda)
Manager

Agarpara Swami Vivekananda Academy
RKV Mission, Agarpara, Kolkata-700058



Government of West Bengal
Office of the Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata – 16

Memo No.:FSR/FS/N 24 PGS DIVN/125/16

Date : 20-05-2024

From :
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To :
Swami Nityarupananda, Secretary, Agarpara Swami Vivekananda Mission under Ramkrishna Vivekananda Mission
3, B.T. Road, Agarpara, Dist - North 24 Parganas, Pin - 700058

Sub : Fire Safety Certificate for an existing School Building comprising TWO numbers of adjoin block of G+II storied as Block-A and G+IV Storied as Block-B under principal group occupancy u201CEducationalu201D in the name & style u2018Agarpara Swami Vivekananda Academy, Under Ramkrishna Vivekanda Missionu201D at Premises No.-3, B.T. Road, Agarpara, Dist-South 24 Parganas, Pin-700058, W.B., India.

This is in reference to your AIN 211892406300000126 dated 03-Apr-2024 regarding Fire Safety Certificate for an existing School Building comprising TWO numbers of adjoin block of G+II storied as Block-A and G+IV Storied as Block-B under principal group occupancy u201CEducationalu201D in the name & style u2018Agarpara Swami Vivekananda Academy, Under Ramkrishna Vivekanda Missionu201D at Premises No.-3, B.T. Road, Agarpara, Dist-South 24 Parganas, Pin-700058, W.B., India..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. The Interior finish decoration of building shall be made with low flame spread material confirming to the I. S. Specification.
3. The Building shall not be used for the storage of any hazardous materials i.e., Volatile flammable



ATTESTED
[Signature]
24/11/24
**HEAD MASTER & SECRETARY
KAMARHATI SAGORE DUTT
FREE HIGH SCHOOL (H.S.)
KOLKATA - 58**

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892406300000126

[Signature]
(Kousik Chattaraj)
Principal
Agarpara Swami Vivekananda Academy
Kolkata - 700058

[Signature]
(Swami Nityarupananda)
Manager
Agarpara Swami Vivekananda Academy
RKV Mission, Agarpara, Kolkata-700058

liquids. If stored then, it shall be restricted to science laboratories only.

4. Rooms used by the preschool, Grade-1 students shall be located on ground floor of exit discharge. Room occupied by class II students shall be located not above one floor higher than ground floor of exit discharge.

5. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outsides of the Building shall be strictly maintained.

6. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.

7. A fire control room including a closed circuit T.V. system will have to maintain to monitor entire the educational Building.

8. The notice of Fire Fighting and Evacuation from the building shall be displayed at all venerable places of the Building.

9. The Teachers, Non-teaching Staffs, employees and security staff shall be conversant with installed fixed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.

10. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.

11. Switch Gear, Transformer, Generator room, Electrical Panel Rooms shall have to be protected by suitable CO-2 or DCP Fire Extinguisher conforming I. S. Specification.

12. A crew of trained Fireman shall be maintained round the clock for safety of the building.

13. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all times.

14. First-Aid-Fire Fighting system shall be provided as per I.S. Specification.

15. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.

16. Electrical Audit shall be conducted by Government approved licence holder Supervisor and certificate must be submitted in the office at the time of renewal of Fire Safety Certificate.

17. The Fire Safety Certificate is valid for three years and has to be renewed after every three year from the date of issue of this letter.

18. The certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services on satisfactory performance of all the life & Fire Safety arrangements and installations of the building.

Memo No.:FSR/FS/N 24 PGS DIVN/125/16
Valid Upto : 19-May-2027

ATTESTED


24/11/23
**HEAD MASTER & SECRETARY
KAMARHATI SAGORE DUTT
FREE HIGH SCHOOL (H.S.)
KOLKATA - 58**




Signature valid

Digitally Signed.
Name: ABHINAV BANDEY
Date: 20-May-2024 15:00:39
Reason: D-Sign
Location: E-Dist 2.0

Director


West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892406300000126


(Kousik Chattaraj)

Principal

Agarpara Swami Vivekananda Academy
Kolkata - 700058


(Swami Nityarupahanda)
Manager

Agarpara Swami Vivekananda Academy
RKV Mission, Agarpara, Kolkata-700058